ACRS MEETING WITH THE U.S. NUCLEAR REGULATORY COMMISSION

April 7, 2005

OVERVIEW

GRAHAM B. WALLIS

Major Accomplishments

- Since our last meeting with the Commission on June 2, 2004, we issued 24 Reports.
- Topics included:
 - -Draft Final 10 CFR 50.69, "Risk-Informed Categorization and Treatment of Structures, Systems, and Components for Nuclear Power Plants"

- Construction authorization request for the MOX Fuel Fabrication Facility
- -Proposed resolution of Generic Safety Issue 185, "Control of Recriticality Following Small-Break LOCAs in PWRs"
- Draft proposed rule on post-fire operator manual actions

Future Plant Designs

- Completed review of the AP1000 design
- Reviewed pre-application submittals for ACR-700 and ESBWR designs
- Issued AP1000 Lessons Learned Letter

Future Plant Designs

- Reviewing proposed technologyneutral framework document for new plant licensing
- Reviewing early site permit applications (North Anna, Clinton, and Grand Gulf sites)

Future Activities

- Risk-informed and performancebased regulation
- Thermal-hydraulic codes
- Materials and metallurgy
- Advanced reactor designs
- Rules and regulatory guidance
- Resolution of GSIs
- Revisions to SRP

Future Activities

- High-burnup fuel issues
- Use of MOX fuel in commercial reactors
- Report on the NRC Safety Research Program
- Assessment of research quality
- Core power uprates

Future Activities


- License renewal applications
- Digital I&C matters
- Fire protection
- Human factors and human reliability assessment
- Operating plant issues

PWR SUMP PERFORMANCE


Graham B. Wallis

PWR Sump Performance

PWR LBLOCA and Sump







ECCS Sump Pit and Debris Screens

PWR Sump Performance

Staff and Industry Activities

- Regulatory Guide 1.82, Revision 3
- Bulletin 2003-01
- Generic Letter 2004-02
- NRC Research Reports
 - Technical Basis Report
 - Pressure drop through filter beds
 - Chemical effects
- NEI Guidance Document and Staff SER

PWR Sump Performance ACRS ISSUES

- RG 1.82, Rev. 3 does not describe methods acceptable to the staff for meeting the requirements
- Generic Letter asks for calculations which are dependent on adequate technical guidance


PWR Sump Performance

ACRS ISSUES


- Guidance contains errors and inadequacies
- Alternative solutions, possibly risk-informed
- Need for additional research


RISK-INFORMING 10 CFR 50.46

George E. Apostolakis



Break Size





Break Size

18

ACRS Comments and Recommendations

- The NUREG Report and the proposed rule should be issued for public comment
- Must demonstrate that coolable geometry is maintained for breaks greater than the TBS
- Any changes to the licensing basis should be consistent with RG 1.174

ACRS Comments and Recommendations

- Bundling of changes in risk due to unrelated changes in the licensing basis should be allowed
- Expert opinion elicitations should seek to produce a composite distribution that represents the group's (and hopefully the community's) judgment and properly reflect the associated uncertainties

ACRS Comments and Recommendations

- Eliciting expert opinions provides input to the decisionmaking process, i.e., the selection of the TBS
- A quantitative understanding of the possible risk benefits as a function of the TBS is needed

PTS REEVALUATION PROJECT — Technical Basis for Revision of the PTS Screening Criterion

William J. Shack

- Irradiation makes reactor pressure vessels more susceptible to failure by thermal shock under some accident sequences
- PTS rule intended to prevent such failures

- Reevaluation project includes:
 - Comprehensive study of scenarios that lead to PTS
 - More realistic evaluation of thermal hydraulics of PTS scenarios
 - More realistic distributions for flaw density and geometry
 - Improved PFM analysis code, FAVOR
 - Systematic consideration of uncertainties

Subcommittee Meetings

Materials and Metallurgy

September 2000 January 2002 May 2002 November 2004

Thermal- Hydraulic Phenomena

January 2001 May 2002 December 2002 November 2004

Reliability & Probabilistic Risk Assessment

May 2002 November 2004

Full Committee Meetings

October 2000 February 2001

February 2002 (Letter to EDO, Feb. 14, 2002)
July 2002 (Letter to EDO, July 18, 2002)
February 2003 (Letter to EDO, Feb 21, 2003)

December 2004

March 2005 (Letter to EDO, March 11, 2005)

ACRS Recommendation

 The acceptance criterion for vessel failure frequency should be based on considerations of large earlyrelease frequency and not on core damage frequency

ACRS Conclusions

- Current PTS screening criterion is very conservative
- Improvements to the PFM code (FAVOR) and characterization of irradiated materials and development of more realistic flaw distributions may also provide a basis for reducing unnecessary conservatism in limits on heatup and cooldown

ACRS Conclusions

- Initial draft technical basis report needed revision to describe more clearly the basic phenomena, issues, approaches, and conclusions
- ACRS supported plans for peer review basis

ACRS Conclusions

- External peer review was valuable, and the staff response to the criticisms and questions has strengthened the technical
- Documentation for the project is not yet final, but significant progress has been made
- Comprehensive technical basis has been developed to revise the PTS Rule

LICENSE RENEWAL/ EXTENDED POWER UPRATES

MARIO V. BONACA

- Performed four interim (subcommittee) reviews and two final (full committee) reviews since June 2004
- Will perform two interim reviews and four final reviews during the remainder of CY 2005
- Will perform seven interim reviews and six final reviews in CY 2006

- Reviewing updates to Generic License Renewal Guidance documents (SRP, GALL Report, and Regulatory Guide)
- Continue to review improvements to the license renewal process
- Will review Interim Staff Guidance on license renewal issues

- ACRS comments and recommendations resulted in:
 - Proposed GL concerning failures of inaccessible/underground cables that disable accident mitigation systems
 - Inclusion of adequate information on TLAAs in applications and independent staff evaluation of TLAAs associated with reactor vessel embrittlement

- Inclusion of steam dryers in scope for Dresden and Quad Cities
- Proposed revisions to GALL Report to ensure that
 - Inspection frequency for buried piping is adequate
 - Aging management of steam dryer cracking due to flow induced vibration is addressed

- Evaluation of operating experience at EPU levels
- RES study on the need for phosphate limits at sites of plants applying for license renewal

Extended Power Uprates

Waterford 3

- 8% EPU
- First use of EPU Review Standard RS-001
- Similar to EPU for ANO-2
- Large-transient testing should be waived because other approaches are more appropriate in this case

Extended Power Uprates

Waterford 3

- Generic concern identified regarding boron concentration and precipitation
- EPU should be authorized

Extended Power Uprates

Upcoming EPU Requests

- Vermont Yankee
- Browns Ferry
- Beaver Valley
- Hope Creek
- Ginna

DIFFERENCES IN REGULATORY APPROACHES BETWEEN U.S. AND OTHER COUNTRIES

Dana A. Powers

Differences In Regulatory Approaches

- Focus on BWRs and PWRs
- Baseline Report by H. Nourbakhsh
- Strong influence of the U.S. regulatory system in many countries
- Great similarities in accepting the principles of traditional deterministic approach

Differences In Regulatory Approaches

- Differences in use of quantitative risk estimates
- Greater attention by Europeans to severe accident management measures
- No major differences in response to:
 - Sump blockage
 - -Vessel head penetration issue

Differences In Regulatory Approaches

 The ACRS will endeavor to keep the Commission informed of significant differences in regulatory requirements between United States and other countries that come to its attention

Abbreviations

ACR Advanced CANDU Reactor

ACRS Advisory Committee on Reactor Safeguards

ANO Arkansas Nuclear One BWR Boiling Water Reactor

CFR Code of Federal Regulations

CY Calendar Year

ECCS Emergency Core Cooling System

EPU Extended Power Uprate

ESBWR Economic Simplified Boiling Water Reactor

GALL Generic Aging Lessons Learned Report

GL Generic Letter

GSI Generic Safety Issue

I&C Instrumentation and Control

LBDEGB Large Break Double Ended Guillotine Break

LBLOCA Large Break Loss-of- Coolant Accident

Abbreviations

LOCA Loss-of-Coolant-Accident

MOX Mixed Oxide

NEI Nuclear Energy Institute

NPSH Net Positive Suction Head

NRC Nuclear Regulatory Commission

PFM Probabilistic Fracture Mechanics

PTS Pressurized Thermal Shock

PWR Pressurized Water Reactor

RES Office of Nuclear Regulatory Research

RG Regulatory Guide

RS Review Standard

SER Safety Evaluation Report

Abbreviations

SRM Staff Requirements Memorandum

SRP Standard Review Plan

TBS Transition Break Size

TLAAs Time Limited Aging Analyses

U.S. United States