

**U.S. Nuclear Regulatory Commission
Human Factors Information System (HFIS)
IR/LER Category Analysis by Docket Report**

Total Number of Hits: 9

National Average: 56

2x National Average: 112

National Median: 25

Average for Selected Dockets: 9

Facility Name: Vogtle 1 Docket (050- 00424)

Details	Department	Work Type	Docket/Report
Oversight / IR			
130 - Inadequate supervision / command and control	O - Operations	O - Control Room Ops	050-00424/2005-002
Number of Items for this Docket: 1			
Percent of Total for this Docket: 11			
Work Planning & Practices / IR			
184 - Tag outs LTA	M - Mechanical	B - Bal of Plant Ops	050-00424/2005-002
188 - Work practice or craft skill LTA	I - Instrumentation & Control	C - Calibration	050-00424/2005-003
188 - Work practice or craft skill LTA	M - Mechanical	M - Maintenance / Repair	050-00424/2005-003
188 - Work practice or craft skill LTA	O - Operations	O - Control Room Ops	050-00424/2005-002
190 - Failure to stop work / non-conservative decision making	I - Instrumentation & Control	C - Calibration	050-00424/2005-003
Number of Items for this Docket: 5			
Percent of Total for this Docket: 56			
Procedures & Reference Document / LER			
111 - Procedure / reference document technical content	I - Instrumentation & Control	M - Maintenance / Repair	050-00424/2005-003-00
111 - Procedure / reference document technical content	M - Mechanical	M - Maintenance / Repair	050-00424/2005-004-00
Number of Items for this Docket: 2			
Percent of Total for this Docket: 22			
Training / LER			
100 - Training LTA	I - Instrumentation & Control	M - Maintenance / Repair	050-00424/2005-003-00
Number of Items for this Docket: 1			
Percent of Total for this Docket: 11			
Total Items for this Docket: 9			
